

CERTIFICATE FI 28205 M1



Our Ref. 270185-1, 270185-2

Product XLPE insulated power cable 10 kV, 20 kV, 36 kV

Type AHXAMK-W
AHXAMK-WP
AHXAMK-WM

Trade mark TF KABLE 5

**Certificate Holder/
Manufacturer** TELE-FONIKA KABLE S.A.
ul. Wielicka 114
PL 30-663 KRAKOW
POLAND

Technical information Number and nominal cross-sectional area of conductors
3 x 35-800 Al + 35-70 Cu

Other information Rated voltage 6/10 (12) kV, 12/20 (24) kV or 18/30 (36) kV

**The product is certified
according to the
following standard(s)** HD 620 S2:2010 Part 10 Section F
SFS 5636:2008

Validity This certificate is valid until 05 September 2018 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.

Date of issue 10 October 2014

SGS Fimko Ltd

Signature



Sixten Lökfors
Project Manager



This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS Fimko Ltd.

Särkiniementie 3 P.O.Box 30 FI-00211 Helsinki, Finland

t. +358 9 696 361 f. +358 9 692 5474 www.sgs.fi

Business ID 0978538-5

Member of the SGS Group (SGS SA)

Appendix to Certificate: 28205 M1

Manufacturing sites

TELE-FONIKA KABLE S.A.
ul. Fordonska 152
PL 85-957 BYDGOSZCZ
POLAND

Additional information

This certificate is based on Type Test Certificate Nos. TK5/IV-6-9/2011, TK5/IV-6-10/2011, TK5/IV-6-11/2011, TK5/IV-6-12/2011, TK5/IV-8-5/2011, and TK5/IV-6-1/2013 by manufacturer and checked and approved by SGS Fimko Ltd. For 18/30 (36) kV additionally checked TK5/IV-5-5/2014 and approved by SGS Fimko Ltd.

This certificate replaces Certificate FI 28205 A1 dated 03 March 2014, due to updated Type and Other information.